FILLING IN THE CONDITION REPORT: THE SECTIONS THAT MATTER

WHAT GOES IN THE SUMMARY OF THE CONDITION?

SECTION	WHAT GOES IN IT
D — Extent and limitations	What is covered, what is not, and why. Continuation sheets if needed
E — Summary of the condition	The **overall** condition of the installation, and the satisfactory/unsatisfactory decision
Supply and particulars sections	Supply characteristics, earthing arrangements, installation particulars — filled in from the documentation
K — Observations	Every observation, each with its code
Schedules	Circuit details and test results — **one set per distribution board**

> ✋ **The summary of the condition of the installation is not a list of observations.** The commonest mistake is copying the observations into it. The summary asks for the general condition of the installation as a whole — which can be "generally in good condition" even with a couple of C2s recorded in the observations.

On the observations tick-box: if any remedial action is required, the **observations** box is ticked. C3 and FI are still observations, so they get ticked too. Any C1 or C2 makes the report unsatisfactory; a C3 on its own does not.

Free section from Sparky Study Notes. The full Level 3 notes, 1,463 practice questions and the video lessons: sparkystudynotes.co.uk