LOOK BEFORE YOU CALCULATE: THE DEMAND AGAINST THE SUPPLY FUSE

CAN YOU CALCULATE A BOARD YOU HAVEN'T LOOKED AT?

Sum of protective devices	130 A — **over** a 100 A fuse
Maximum demand	**71.2 A** — comfortably inside 100 A, and inside **80 A** too

DNO cut-out fuses are typically **80 A** or **100 A**. If the demand will not fit, the options are to reduce it, to refuse the work, or to ask the DNO for a **second phase** or a **three-phase supply** — which is possible and expensive.

Free section from Sparky Study Notes. The full Level 3 notes, 1,463 practice questions and the video lessons: sparkystudynotes.co.uk