THE SCHEDULE OF INSPECTIONS

WHERE DO YOU FIND WHAT EACH INSPECTION COVERS?

On the certificate there's a list of items to inspect, and for the fundamentals assessment there are **14 outcomes**. Each one gets a **tick** or an **N/A**. That's it.

📕 **BS 7671, Appendix 6** lists the items to inspect under each heading. **Guidance Note 3** has its own inspection checklist (2.5.3, p.47) and the form with the 14 items (Fig 5.2, p.148).

WORKED EXAMPLE: OUTCOME 1

"Condition of consumer's intake equipment (Visual inspection only)"
Appendix 6 lists two points:

- Are there meter tails?
- Is there a means of isolation?

Both present → **tick**

"Means of isolation" — which one?

The supplier's cut-out fuse, a separate isolator, or the main switch. Nobody is touching the DNO fuse, so it's your **main switch** or a separate isolator. The certificate lumps them together and says "where necessary".

🖐 **No condition codes here.** C1, C2, C3 and FI, and limitations, belong on a **condition report** — a periodic. This is a new installation or an addition, so it's ticks and N/As only.

BS 7671 · Appendix 6 · checklist of items to inspect ★

GN3 · Section 5 · the schedule of inspections

Free section from Sparky Study Notes. The full Level 3 notes, 1,463 practice questions and the video lessons: sparkystudynotes.co.uk